

CLASSIFIED STRUCTURE FIELD INVENTORY REPORT
(Attach 4" x 5" Black and White Photograph)

12722

REGION RMR PARK/AREA NAME Zion National Park PARK NUMBER 1590
STRUCTURE NAME East Entrance Checking Station STRUCTURE NUMBER 58
LOCATION OF STRUCTURE East Entrance PARK LOCATION CODE EE
NATIONAL REGISTER _____ DATE: / / MANAGEMENT CATEGORY: (A) (B) (C) ()
NPS LEGAL INTEREST FEE MANAGEMENT AGREEMENT: _____

Check all of the following categories for which NPS has treatment responsibility:
Stabilization() Cyclic Maintenance() Routine Maintenance() Approved Ultimate Treatment()

(ROCKY MOUNTAIN REGION USE ONLY)

APPROVED ULTIMATE TREATMENT OR RESOURCE MANAGEMENT PLAN, CULTURAL COMPONENT DESIGNATION

Preservation (PP) Restoration (RR) Reconstruction (CC)
Adaptive Preservation (AP) Adaptive Restoration (AR) Adaptive Reconstruction (AC)
Neglect (NG) Remove (RM) No Approved Treatment (NO)

Approval Document _____ () Document Date: / /
Estimated Treatment Costs _____

Stabilization: \$ _____ Date: / / Level of Estimate: (A) (B) (C)
Approved Treatment: \$ _____ Date: / / Estimator: (Region) (DSC) (A&E)

STATEMENT OF SIGNIFICANCE:

Date of Construction: / /1934 Date of Alterations: / /
Architect/Designer: _____ Historical Theme(s): NPS rustic
History of Structure: The East Entrance Checking Station was constructed in 1935 at a cost of \$1,000. It was built by enrollees from CCC Camp NP-2, stationed at Zion, of rock quarried at the Zion Stone Quarry. It has served as the entrance station since the Park Service first developed the East Entrance, four years after the completion of the Zion-Mt. Carmel Highway.

Evaluation of Structure: Historic Theme Contributing X Non-Contributing _____
National Register Criteria: A B C *D (Include integrity statement)
The station retains its original appearance and character, fabric, and construction, all typical of NPS-Rustic buildings at Zion.

Bibliography: Form 10-768 (maintenance file); Olivieri, Lance, LCS inventory, 1976;

Representation in Other Surveys: LCS inventory, 1976;

If structure has been removed, how? _____ Date: / /

Report prepared by: Nancy Witherell Date: 10 / 10 / 84

LOCATION: Section _____ State _____ USE: CURRENT INTERIOR USE (NPS 28 CODE) VC
 Township _____ County _____ Original Use _____ VC
 Range _____ Intermediate Uses _____ VC
 PERIOD OF CONSTRUCTION (NPS 28 CODE) HI


OWNERSHIP: Present Owner: _____ NPS
 Original Owner: _____ NPS
 Intermediate Owner(s): _____ NPS
 NEGATIVE No. ROLL #18, VIEW 0A

PHYSICAL DESCRIPTION

TYPE OF STRUCTURE (NPS 28 CODE): BU CHIMNEYS: red sandstone chimney.
 ARCHITECTURAL CHARACTER (STYLE): NPS-Rustic style
 SITE (INCLUDE ORIENTATION OF STRUCTURE): Checking station PORCHES: none
 is sited on island in the middle of Route 9, with
 long facades parallel to road.
 OVERALL BUILDING PLAN (FOOTPRINT): rectangular WINDOWS: 6-light, double casement windows on two facades,
 E and W.
 OVERALL DIMENSIONS: 14'x10'
 COMPOSITION (NPS 28 CODE): ST DOORS: one wood panel door on each street facade (N and S)
 STORIES: One.
 FOUNDATION: red sandstone. Curbing of island consists of ADDITIONS: none
 small red sandstone blocks along 135' length. Island
 is 13' wide at center, and comes to a point at either
 end.
 WALLS: Walls are red sandstone, rock-faced ashlar, and INTERIOR PLAN: single rectangular space
 are coursed with large joints with untinted mortar.
 Lower courses are stepped.
 ROOF: Gable roof with wood shakes. Roof eaves extend INTERIOR FINISHES: cement floor, plaster ceiling and walls.
 2'6" over 6"x6" beams with braces, and 2"x6"
 rafter ends. Gable ends on E and W facades
 are clapboarded.

SIGNIFICANT ARCHITECTURAL FEATURES (INCLUDING INTERIOR AND SETTING) FOR PARK PLANNING PURPOSES:

Stonework and roof elements are original; windows are original; stonework curbing on island is original.



Roll No. HS-58

Photo No. Roll #18, View OA

Subject East Entrance Checking
Station

Descrip. of View Southeast

Location of Subject East Entrance

Location of Negative RMRO

By Nancy Witherall

Date 8/84